



# POWER CORD

## Quick Installation Guide for Compaq High Voltage Power Distribution Unit



Printed on recycled paper

### NOTICE

The information in this publication is subject to change without notice.

COMPAQ COMPUTER CORPORATION SHALL NOT BE LIABLE FOR TECHNICAL OR EDITORIAL ERRORS OR OMISSIONS CONTAINED HEREIN, NOR FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES RESULTING FROM THE FURNISHING, PERFORMANCE, OR USE OF THIS MATERIAL. THIS INFORMATION IS PROVIDED "AS IS" AND COMPAQ COMPUTER CORPORATION DISCLAIMS ANY WARRANTIES, EXPRESS, IMPLIED OR STATUTORY AND EXPRESSLY DISCLAIMS THE IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR PARTICULAR PURPOSE, GOOD TITLE, AND AGAINST INFRINGEMENT.

This publication contains information protected by copyright. No part of this publication may be photocopied or reproduced in any form without prior written consent from Compaq Computer Corporation.

© 2000 Compaq Computer Corporation  
All rights reserved. Printed in the U.S.A.

Compaq, Registered U.S. Patent and Trademark Office.

COMPAQ POWER CORD KIT QUICK INSTALLATION GUIDE  
FOR COMPAQ HIGH VOLTAGE POWER DISTRIBUTION UNIT

First Edition (April 2000)  
Part Number 191692-021

Compaq Computer Corporation

BAR CODE

## About This Guide

Use this guide when installing the enclosed 16 amp IEC to IEC power cord for connectivity between the Compaq High Voltage Power Distribution Unit (PDU) model (Compaq part number 295633-B21) and the Compaq R3000H Uninterruptible Power System (UPS) or the Compaq 6000 Series UPS.

## Safety Precautions



### Important Safety Information

Read Before Installing Product

Please refer to the *Important Safety Information* guide (included with the PDU kit) before installing this product.




#### WARNING:

- There is a risk of personal injury from electric shock and hazardous energy levels. The installation of this power cord must be performed by individuals who are knowledgeable about the procedures, precautions, and hazards associated with AC Power Products.
- The PDU increases the number of output receptacles on the UPS and can be overloaded if too many devices are connected to it. Pay close attention to the electrical ratings of all devices connected and do not exceed the output rating of the UPS.
- Please refer to the Operation and Reference Guide included with the Compaq UPS for additional information on this product.

## Installation

Install the power cord (Compaq part number 242867-001) as shown below. To order additional cables, use Compaq part number 295633-B21.



Compaq R3000H UPS

Compaq 6000 Series UPS